

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 13)**

Water Level of the accumulated water (at 16:00 on July 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,327 mm (1 mm decrease since 7:00 on July 13)	O.P.+ 3,389 mm (1 mm decrease since 7:00 on July 13)	—
	Water level of Turbine Building	O.P.+ 3,149 mm (13 mm increase since 7:00 on July 13)	O.P.+ 3,251 mm (1 mm decrease since 7:00 on July 13)	O.P.+ 3,284 mm (3 mm decrease since 7:00 on July 13)	O.P.+ 3,275 mm (No change since 7:00 on July 13)
	Water level of Reactor Building	O.P.+ 4,758 mm (38 mm decrease since 7:00 on July 13)	O.P.+ 3,474 mm (2 mm decrease since 7:00 on July 13)	O.P.+ 3,402 mm (3 mm decrease since 7:00 on July 13)	O.P.+ 3,278 mm (No change since 7:00 on July 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,457 mm (Increase from initial level:5,674 mm, 4 mm increase since 7:00 on July 13) O.P.+ 3,418 mm (Increase from initial level:4,144 mm, 75 mm increase since 7:00 on July 13) O.P.+ 4,444 mm (Water level from floor:648 mm, 2 mm increase since 7:00 on July 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on July 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:31 on July 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:17 on July 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.