

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 17)**

Water Level of the accumulated water (at 7:00 on July 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,341 mm (8 mm decrease since 16:00 on July 16)	O.P.+ 3,397 mm (20 mm increase since 16:00 on July 16)	—
	Water level of Turbine Building	O.P.+ 2,905 mm (19 mm increase since 16:00 on July 16)	O.P.+ 3,263 mm (7 mm decrease since 16:00 on July 16)	O.P.+ 3,302 mm (22 mm increase since 16:00 on July 16)	O.P.+ 3,263 mm (7 mm increase since 16:00 on July 16)
	Water level of Reactor Building	O.P.+ 4,563 mm (6 mm decrease since 16:00 on July 16)	O.P.+ 3,488 mm (7 mm decrease since 16:00 on July 16)	O.P.+ 3,423 mm (23 mm increase since 16:00 on July 16)	O.P.+ 3,266 mm (6 mm increase since 16:00 on July 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,678 mm (Increase from initial level:5,895 mm, 4 mm increase since 16:00 on July 16) O.P.+ 3,138 mm (Increase from initial level:3,864 mm, 192 mm decrease since 16:00 on July 16) O.P.+ 4,452 mm (Water level from floor:656 mm, 1 mm increase since 16:00 on July 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on July 12)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:17 on July 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:21 AM on July 17, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.