

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 17)**

Water Level of the accumulated water (at 16:00 on July 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,336 mm (5 mm decrease since 7:00 on July 17)	O.P.+ 3,405 mm (8 mm increase since 7:00 on July 17)	—
	Water level of Turbine Building	O.P.+ 2,917 mm (12 mm increase since 7:00 on July 17)	O.P.+ 3,260 mm (3 mm decrease since 7:00 on July 17)	O.P.+ 3,313 mm (11 mm increase since 7:00 on July 17)	O.P.+ 3,270 mm (7 mm increase since 7:00 on July 17)
	Water level of Reactor Building	O.P.+ 4,548 mm (15 mm decrease since 7:00 on July 17)	O.P.+ 3,484 mm (4 mm decrease since 7:00 on July 17)	O.P.+ 3,434 mm (11 mm increase since 7:00 on July 17)	O.P.+ 3,273 mm (7 mm increase since 7:00 on July 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,679 mm (Increase from initial level:5,896 mm, 1 mm increase since 7:00 on July 17) O.P.+ 3,341 mm (Increase from initial level:4,067 mm, 203 mm increase since 7:00 on July 17) O.P.+ 4,453 mm (Water level from floor:657 mm, 1 mm increase since 7:00 on July 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on July 12)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:35 on July 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:21 AM on July 17, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. After the filter cleaning, the apparatus was restarted at 1:35 PM on the same day. Control plate modification of the desalination system (reverse osmosis membrane) was conducted with this stopping. Since we confirmed the need to modify the program of the software which would be altered, we will continue the work tomorrow.				

For quick publication of the data of water level, values are provided as reference values.