

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 18)**

Water Level of the accumulated water (at 7:00 on July 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,326 mm (10 mm decrease since 16:00 on July 17)	O.P.+ 3,419 mm (14 mm increase since 16:00 on July 17)	—
	Water level of Turbine Building	O.P.+ 2,935 mm (18 mm increase since 16:00 on July 17)	O.P.+ 3,251 mm (9 mm decrease since 16:00 on July 17)	O.P.+ 3,328 mm (15 mm increase since 16:00 on July 17)	O.P.+ 3,283 mm (13 mm increase since 16:00 on July 17)
	Water level of Reactor Building	O.P.+ 4,515 mm (33 mm decrease since 16:00 on July 17)	O.P.+ 3,478 mm (6 mm decrease since 16:00 on July 17)	O.P.+ 3,454 mm (20 mm increase since 16:00 on July 17)	O.P.+ 3,285 mm (12 mm increase since 16:00 on July 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,683 mm (Increase from initial level:5,900 mm, 4 mm increase since 16:00 on July 17) O.P.+ 3,143 mm (Increase from initial level:3,869 mm, 198 mm decrease since 16:00 on July 17) O.P.+ 4,454 mm (Water level from floor:658 mm, 1 mm increase since 16:00 on July 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:43 on July 12)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): From 13:35 on July 17 to 7:23 on July 18 Stop Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:23 AM on July 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for control plate modification of the desalination system (reverse osmosis membrane).				

For quick publication of the data of water level, values are provided as reference values.