

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 18)**

Water Level of the accumulated water (at 16:00 on July 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,349 mm (23 mm increase since 7:00 on July 18)	O.P.+ 3,417 mm (2 mm decrease since 7:00 on July 18)	—
	Water level of Turbine Building	O.P.+ 2,945 mm (10 mm increase since 7:00 on July 18)	O.P.+ 3,270 mm (19 mm increase since 7:00 on July 18)	O.P.+ 3,321 mm (7 mm decrease since 7:00 on July 18)	O.P.+ 3,289 mm (6 mm increase since 7:00 on July 18)
	Water level of Reactor Building	O.P.+ 4,476 mm (39 mm decrease since 7:00 on July 18)	O.P.+ 3,484 mm (6 mm increase since 7:00 on July 18)	O.P.+ 3,454 mm (No change since 7:00 on July 18)	O.P.+ 3,290 mm (5 mm increase since 7:00 on July 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,686 mm (Increase from initial level:5,903 mm, 3 mm increase since 7:00 on July 18) O.P.+ 3,344 mm (Increase from initial level:4,070 mm, 201 mm increase since 7:00 on July 18) O.P.+ 4,454 mm (Water level from floor:658 mm, No change since 7:00 on July 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:43 on July 12 to 10:06 on July 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:24 on July 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:35 on July 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:23 AM on July 18, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for control panel modification of the desalination system (reverse osmosis membrane). After the modification, we restarted the desalination system (reverse osmosis membrane) which was stopped at 3:25 PM on July 17, and restarted the second Cesium Adsorption Apparatus (SARRY) subsequently at 4:35 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.