

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 20)**

Water Level of the accumulated water (at 16:00 on July 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,272 mm (7 mm decrease since 7:00 on July 20)	O.P.+ 3,301 mm (6 mm decrease since 7:00 on July 20)	—
	Water level of Turbine Building	O.P.+ 2,999 mm (9 mm increase since 7:00 on July 20)	O.P.+ 3,289 mm (8 mm decrease since 7:00 on July 20)	O.P.+ 3,289 mm (3 mm decrease since 7:00 on July 20)	O.P.+ 3,281 mm (4 mm decrease since 7:00 on July 20)
	Water level of Reactor Building	O.P.+ 4,457 mm (15 mm decrease since 7:00 on July 20)	O.P.+ 3,514 mm (6 mm decrease since 7:00 on July 20)	O.P.+ 3,428 mm (4 mm decrease since 7:00 on July 20)	O.P.+ 3,286 mm (3 mm decrease since 7:00 on July 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,699 mm (Increase from initial level:5,916 mm, 2 mm increase since 7:00 on July 20) O.P.+ 3,509 mm (Increase from initial level:4,235 mm, 95 mm increase since 7:00 on July 20) O.P.+ 4,460 mm (Water level from floor:664 mm, 1 mm increase since 7:00 on July 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:32 on July 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:24 on July 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:35 on July 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.