

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 23)**

Water Level of the accumulated water (at 7:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,215 mm (13 mm decrease since 16:00 on July 22)	O.P.+ 3,328 mm (15 mm increase since 16:00 on July 22)	—
	Water level of Turbine Building	O.P.+ 3,060 mm (14 mm increase since 16:00 on July 22)	O.P.+ 3,240 mm (11 mm decrease since 16:00 on July 22)	O.P.+ 3,328 mm (14 mm increase since 16:00 on July 22)	O.P.+ 3,292 mm (12 mm increase since 16:00 on July 22)
	Water level of Reactor Building	O.P.+ 4,402 mm (5 mm decrease since 16:00 on July 22)	O.P.+ 3,466 mm (12 mm decrease since 16:00 on July 22)	O.P.+ 3,469 mm (16 mm increase since 16:00 on July 22)	O.P.+ 3,294 mm (11 mm increase since 16:00 on July 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,715 mm (Increase from initial level:5,932 mm, 4 mm increase since 16:00 on July 22) O.P.+ 3,293 mm (Increase from initial level:4,019 mm, 181 mm decrease since 16:00 on July 22) O.P.+ 4,466 mm (Water level from floor:670 mm, 2 mm increase since 16:00 on July 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:32 on July 19)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:35 on July 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.