

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 23)**

Water Level of the accumulated water (at 16:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,208 mm (7 mm decrease since 7:00 on July 23)	O.P.+ 3,334 mm (6 mm increase since 7:00 on July 23)	—
	Water level of Turbine Building	O.P.+ 3,068 mm (8 mm increase since 7:00 on July 23)	O.P.+ 3,233 mm (7 mm decrease since 7:00 on July 23)	O.P.+ 3,339 mm (11 mm increase since 7:00 on July 23)	O.P.+ 3,299 mm (7 mm increase since 7:00 on July 23)
	Water level of Reactor Building	O.P.+ 4,391 mm (11 mm decrease since 7:00 on July 23)	O.P.+ 3,460 mm (6 mm decrease since 7:00 on July 23)	O.P.+ 3,476 mm (7 mm increase since 7:00 on July 23)	O.P.+ 3,300 mm (6 mm increase since 7:00 on July 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,719 mm (Increase from initial level:5,936 mm, 4 mm increase since 7:00 on July 23) O.P.+ 3,214 mm (Increase from initial level:3,940 mm, 79 mm decrease since 7:00 on July 23) O.P.+ 4,467 mm (Water level from floor:671 mm, 1 mm increase since 7:00 on July 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:32 on July 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:35 on July 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.