

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 24)**

Water Level of the accumulated water (at 7:00 on July 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (13 mm decrease since 16:00 on July 23)	O.P.+ 3,325 mm (9 mm decrease since 16:00 on July 23)	—
	Water level of Turbine Building	O.P.+ 3,081 mm (13 mm increase since 16:00 on July 23)	O.P.+ 3,221 mm (12 mm decrease since 16:00 on July 23)	O.P.+ 3,315 mm (24 mm decrease since 16:00 on July 23)	O.P.+ 3,301 mm (2 mm increase since 16:00 on July 23)
	Water level of Reactor Building	O.P.+ 4,401 mm (10 mm increase since 16:00 on July 23)	O.P.+ 3,448 mm (12 mm decrease since 16:00 on July 23)	O.P.+ 3,462 mm (14 mm decrease since 16:00 on July 23)	O.P.+ 3,303 mm (3 mm increase since 16:00 on July 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,722 mm (Increase from initial level:5,939 mm, 3 mm increase since 16:00 on July 23) O.P.+ 3,380 mm (Increase from initial level:4,106 mm, 166 mm increase since 16:00 on July 23) O.P.+ 4,469 mm (Water level from floor:673 mm, 2 mm increase since 16:00 on July 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:32 on July 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:30 on July 24 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:30 AM on July 24, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.