## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 25)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on July 25)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,286 mm (27 mm increase since 7:00 on July 25)	O.P.+ 3,314 mm (3 mm decrease since 7:00 on July 25)	_
	Water level of Turbine Building	O.P.+ 3,110 mm (7 mm increase since 7:00 on July 25)	O.P.+ 3,303 mm (33 mm increase since 7:00 on July 25)	O.P.+ 3,299 mm (5 mm decrease since 7:00 on July 25)	O.P.+ 3,291 mm (3 mm decrease since 7:00 on July 25)
	Water level of Reactor Building	O.P.+ 4,379 mm (7 mm decrease since 7:00 on July 25)	O.P.+ 3,515 mm (24 mm increase since 7:00 on July 25)	O.P.+ 3,441 mm (3 mm decrease since 7:00 on July 25)	O.P.+ 3,295 mm (2 mm decrease since 7:00 on July 25)
	Water level	Process Main Building	O.P.+ 4,730 mm (Increase from initial level:5,947 mm, 6 mm increase since 7:00 on July 25)		
	of each building in the Centralized Radiation Waste Treatment Facility	High Temperature Incinerator Building	O.P.+ 3,412 mm (Increase from initial level:4,138 mm, 161 mm decrease since 7:00 on July 25)		
		On-site Bunker Building	O.P.+ 4,472 mm (Water level from floor:676 mm, 1 mm increase since 7:00 on July 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building  →Centralized Radiation Waste  Treatment Facility (High  Temperature Incinerator Building)  Currently being transferred  (Since 14:52 on July 23)	_
		Unit 5 and 6			
			-	_	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					
			For a	uick publication of the data of water level.	values are provided as reference values