

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 26)**

Water Level of the accumulated water (at 7:00 on July 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,328 mm (42 mm increase since 16:00 on July 25)	O.P.+ 3,309 mm (5 mm decrease since 16:00 on July 25)	—
	Water level of Turbine Building	O.P.+ 3,123 mm (13 mm increase since 16:00 on July 25)	O.P.+ 3,341 mm (38 mm increase since 16:00 on July 25)	O.P.+ 3,291 mm (8 mm decrease since 16:00 on July 25)	O.P.+ 3,284 mm (7 mm decrease since 16:00 on July 25)
	Water level of Reactor Building	O.P.+ 4,398 mm (19 mm increase since 16:00 on July 25)	O.P.+ 3,552 mm (37 mm increase since 16:00 on July 25)	O.P.+ 3,432 mm (9 mm decrease since 16:00 on July 25)	O.P.+ 3,288 mm (7 mm decrease since 16:00 on July 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,735 mm (Increase from initial level:5,952 mm, 5 mm increase since 16:00 on July 25) O.P.+ 3,130 mm (Increase from initial level:3,856 mm, 282 mm decrease since 16:00 on July 25) O.P.+ 4,474 mm (Water level from floor:678 mm, 2 mm increase since 16:00 on July 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.