

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 26)**

Water Level of the accumulated water (at 16:00 on July 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,354 mm (26 mm increase since 7:00 on July 26)	O.P.+ 3,306 mm (3 mm decrease since 7:00 on July 26)	—
	Water level of Turbine Building	O.P.+ 3,131 mm (8 mm increase since 7:00 on July 26)	O.P.+ 3,363 mm (22 mm increase since 7:00 on July 26)	O.P.+ 3,289 mm (2 mm decrease since 7:00 on July 26)	O.P.+ 3,282 mm (2 mm decrease since 7:00 on July 26)
	Water level of Reactor Building	O.P.+ 4,398 mm (No change since 7:00 on July 26)	O.P.+ 3,575 mm (23 mm increase since 7:00 on July 26)	O.P.+ 3,429 mm (3 mm decrease since 7:00 on July 26)	O.P.+ 3,286 mm (2 mm decrease since 7:00 on July 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,803 mm (Increase from initial level:6,020 mm, 68 mm increase since 7:00 on July 26) O.P.+ 2,982 mm (Increase from initial level:3,708 mm, 148 mm decrease since 7:00 on July 26) O.P.+ 4,264 mm (Water level from floor:468 mm, 210 mm decrease since 7:00 on July 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 9:51 AM to 4:19 PM on July 26: Accumulated water was transferred from the On-site Bunker Building to the Process Main Building.				

For quick publication of the data of water level, values are provided as reference values.