

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 27)**

Water Level of the accumulated water (at 7:00 on July 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,394 mm (40 mm increase since 16:00 on July 26)	O.P.+ 3,298 mm (8 mm decrease since 16:00 on July 26)	—
	Water level of Turbine Building	O.P.+ 3,144 mm (13 mm increase since 16:00 on July 26)	O.P.+ 3,399 mm (36 mm increase since 16:00 on July 26)	O.P.+ 3,281 mm (8 mm decrease since 16:00 on July 26)	O.P.+ 3,275 mm (7 mm decrease since 16:00 on July 26)
	Water level of Reactor Building	O.P.+ 4,441 mm (43 mm increase since 16:00 on July 26)	O.P.+ 3,610 mm (35 mm increase since 16:00 on July 26)	O.P.+ 3,421 mm (8 mm decrease since 16:00 on July 26)	O.P.+ 3,280 mm (6 mm decrease since 16:00 on July 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,813 mm (Increase from initial level:6,030 mm, 10 mm increase since 16:00 on July 26) O.P.+ 2,742 mm (Increase from initial level:3,468 mm, 240 mm decrease since 16:00 on July 26) O.P.+ 4,249 mm (Water level from floor:453 mm, 15 mm decrease since 16:00 on July 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:22 on July 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.