

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 27)**

Water Level of the accumulated water (at 16:00 on July 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,382 mm (12 mm decrease since 7:00 on July 27)	O.P.+ 3,296 mm (2 mm decrease since 7:00 on July 27)	—
	Water level of Turbine Building	O.P.+ 3,151 mm (7 mm increase since 7:00 on July 27)	O.P.+ 3,389 mm (10 mm decrease since 7:00 on July 27)	O.P.+ 3,278 mm (3 mm decrease since 7:00 on July 27)	O.P.+ 3,271 mm (4 mm decrease since 7:00 on July 27)
	Water level of Reactor Building	O.P.+ 4,428 mm (13 mm decrease since 7:00 on July 27)	O.P.+ 3,613 mm (3 mm increase since 7:00 on July 27)	O.P.+ 3,417 mm (4 mm decrease since 7:00 on July 27)	O.P.+ 3,277 mm (3 mm decrease since 7:00 on July 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,816 mm (Increase from initial level:6,033 mm, 3 mm increase since 7:00 on July 27) O.P.+ 2,777 mm (Increase from initial level:3,503 mm, 35 mm increase since 7:00 on July 27) O.P.+ 4,250 mm (Water level from floor:454 mm, 1 mm increase since 7:00 on July 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:22 on July 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:52 on July 23)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.