

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 30)**

Water Level of the accumulated water (at 7:00 on July 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,303 mm (19 mm decrease since 16:00 on July 29)	O.P.+ 3,297 mm (13 mm increase since 16:00 on July 29)	—
	Water level of Turbine Building	O.P.+ 3,201 mm (11 mm increase since 16:00 on July 29)	O.P.+ 3,319 mm (15 mm decrease since 16:00 on July 29)	O.P.+ 3,293 mm (17 mm increase since 16:00 on July 29)	O.P.+ 3,260 mm (7 mm increase since 16:00 on July 29)
	Water level of Reactor Building	O.P.+ 4,438 mm (10 mm increase since 16:00 on July 29)	O.P.+ 3,540 mm (18 mm decrease since 16:00 on July 29)	O.P.+ 3,427 mm (18 mm increase since 16:00 on July 29)	O.P.+ 3,264 mm (6 mm increase since 16:00 on July 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,831 mm (Increase from initial level:6,048 mm, 4 mm increase since 16:00 on July 29) O.P.+ 2,789 mm (Increase from initial level:3,515 mm, 199 mm decrease since 16:00 on July 29) O.P.+ 4,256 mm (Water level from floor:460 mm, 1 mm increase since 16:00 on July 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:22 on July 27)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 18:38 on July 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.