

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 31)**

Water Level of the accumulated water (at 7:00 on July 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,277 mm (17 mm decrease since 16:00 on July 30)	O.P.+ 3,316 mm (10 mm increase since 16:00 on July 30)	—
	Water level of Turbine Building	O.P.+ 3,219 mm (11 mm increase since 16:00 on July 30)	O.P.+ 3,294 mm (16 mm decrease since 16:00 on July 30)	O.P.+ 3,312 mm (11 mm increase since 16:00 on July 30)	O.P.+ 3,277 mm (10 mm increase since 16:00 on July 30)
	Water level of Reactor Building	O.P.+ 4,417 mm (9 mm decrease since 16:00 on July 30)	O.P.+ 3,517 mm (17 mm decrease since 16:00 on July 30)	O.P.+ 3,451 mm (14 mm increase since 16:00 on July 30)	O.P.+ 3,279 mm (10 mm increase since 16:00 on July 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,838 mm (Increase from initial level:6,055 mm, 5 mm increase since 16:00 on July 30) O.P.+ 2,543 mm (Increase from initial level:3,269 mm, 153 mm decrease since 16:00 on July 30) O.P.+ 4,257 mm (Water level from floor:461 mm, 1 mm increase since 16:00 on July 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 8:22 on July 27)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on July 31   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	-At 8:34 AM on July 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.