

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 31)**

Water Level of the accumulated water (at 16:00 on July 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,297 mm (20 mm increase since 7:00 on July 31)	O.P.+ 3,313 mm (3 mm decrease since 7:00 on July 31)	—
	Water level of Turbine Building	O.P.+ 3,226 mm (7 mm increase since 7:00 on July 31)	O.P.+ 3,313 mm (19 mm increase since 7:00 on July 31)	O.P.+ 3,306 mm (6 mm decrease since 7:00 on July 31)	O.P.+ 3,281 mm (4 mm increase since 7:00 on July 31)
	Water level of Reactor Building	O.P.+ 4,395 mm (22 mm decrease since 7:00 on July 31)	O.P.+ 3,522 mm (5 mm increase since 7:00 on July 31)	O.P.+ 3,446 mm (5 mm decrease since 7:00 on July 31)	O.P.+ 3,283 mm (4 mm increase since 7:00 on July 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,840 mm (Increase from initial level:6,057 mm, 2 mm increase since 7:00 on July 31) O.P.+ 2,563 mm (Increase from initial level:3,289 mm, 20 mm increase since 7:00 on July 31) O.P.+ 4,258 mm (Water level from floor:462 mm, 1 mm increase since 7:00 on July 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 8:22 on July 27 to 9:31 on July 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (On-site Bunker Building) Currently being transferred (Since 9:47 on July 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:09 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:34 AM on July 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. After the filter cleaning, the apparatus was restarted at 12:09 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.