

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 1)**

Water Level of the accumulated water (at 7:00 on August 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,339 mm (42 mm increase since 16:00 on July 31)	O.P.+ 3,305 mm (8 mm decrease since 16:00 on July 31)	—
	Water level of Turbine Building	O.P.+ 3,237 mm (11 mm increase since 16:00 on July 31)	O.P.+ 3,349 mm (36 mm increase since 16:00 on July 31)	O.P.+ 3,288 mm (18 mm decrease since 16:00 on July 31)	O.P.+ 3,277 mm (4 mm decrease since 16:00 on July 31)
	Water level of Reactor Building	O.P.+ 4,397 mm (2 mm increase since 16:00 on July 31)	O.P.+ 3,559 mm (37 mm increase since 16:00 on July 31)	O.P.+ 3,429 mm (17 mm decrease since 16:00 on July 31)	O.P.+ 3,280 mm (3 mm decrease since 16:00 on July 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,843 mm (Increase from initial level:6,060 mm, 3 mm increase since 16:00 on July 31) O.P.+ 2,369 mm (Increase from initial level:3,095 mm, 194 mm decrease since 16:00 on July 31) O.P.+ 4,259 mm (Water level from floor:463 mm, 1 mm increase since 16:00 on July 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:47 on July 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:09 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- We announced that the destination of the acclumulated water which was transfered from the basement of Unit 3 turbine building was "Centralized Radiation Waste Treatment Facility (On-site Bunker Building)" in "Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 31)". We would like to correct it as "Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)." We sincerely apologize for the mistake.				

For quick publication of the data of water level, values are provided as reference values.