

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 2)**

Water Level of the accumulated water (at 7:00 on August 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,316 mm (24 mm decrease since 16:00 on August 1)	O.P.+ 3,294 mm (7 mm decrease since 16:00 on August 1)	—
	Water level of Turbine Building	O.P.+ 3,252 mm (8 mm increase since 16:00 on August 1)	O.P.+ 3,330 mm (20 mm decrease since 16:00 on August 1)	O.P.+ 3,273 mm (8 mm decrease since 16:00 on August 1)	O.P.+ 3,267 mm (7 mm decrease since 16:00 on August 1)
	Water level of Reactor Building	O.P.+ 4,396 mm (16 mm increase since 16:00 on August 1)	O.P.+ 3,550 mm (21 mm decrease since 16:00 on August 1)	O.P.+ 3,413 mm (8 mm decrease since 16:00 on August 1)	O.P.+ 3,271 mm (6 mm decrease since 16:00 on August 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,849 mm (Increase from initial level:6,066 mm, 3 mm increase since 16:00 on August 1) O.P.+ 2,442 mm (Increase from initial level:3,168 mm, 93 mm increase since 16:00 on August 1) O.P.+ 4,261 mm (Water level from floor:465 mm, 1 mm increase since 16:00 on August 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:13 on August 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:47 on July 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:09 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.