

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 3)**

|   |  |  |  |   |   |
|---|--|--|--|---|---|
| Water Level of the accumulated water<br>(at 7:00 on August 3) |  | Unit 1   | Unit 2   | Unit 3  | Unit 4  |
|   | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,285 mm<br>(20 mm decrease since 16:00 on August 2)   | O.P.+ 3,282 mm<br>(8 mm decrease since 16:00 on August 2)   | —   |
|   | Water level of Turbine Building  | O.P.+ 3,270 mm<br>(11 mm increase since 16:00 on August 2)   | O.P.+ 3,301 mm<br>(19 mm decrease since 16:00 on August 2)   | O.P.+ 3,256 mm<br>(11 mm decrease since 16:00 on August 2)  | O.P.+ 3,255 mm<br>(8 mm decrease since 16:00 on August 2) |
|   | Water level of Reactor Building  | O.P.+ 4,382 mm<br>(7 mm increase since 16:00 on August 2)  | O.P.+ 3,524 mm<br>(18 mm decrease since 16:00 on August 2)   | O.P.+ 3,395 mm<br>(10 mm decrease since 16:00 on August 2)  | O.P.+ 3,260 mm<br>(7 mm decrease since 16:00 on August 2) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 4,855 mm (Increase from initial level:6,072 mm, 3 mm increase since 16:00 on August 2)<br>O.P.+ 2,589 mm (Increase from initial level:3,315 mm, 89 mm increase since 16:00 on August 2)<br>O.P.+ 4,263 mm (Water level from floor:467 mm, 1 mm increase since 16:00 on August 2) |   |   |
| Situation of transfer of the accumulated water                |  | Unit 1   | Unit 2   | Unit 3  | Unit 4  |
|   |  | —  | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred (Since 11:13 on August 1)  | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred (Since 9:47 on July 31) | —   |
|   |  | Unit 5 and 6   |  |   |   |
|   |  | —  |  |   |   |
| Operation condition of water treatment facility               |  | Cesium Adsorption Apparatus: Since 12:05 on June 21   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 12:09 on July 31   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |   |   |
| Notes   |  |  |  |   |   |

For quick publication of the data of water level, values are provided as reference values.