

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 7)**

Water Level of the accumulated water (at 7:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,248 mm (20 mm decrease since 16:00 on August 6)	O.P.+ 3,249 mm (8 mm decrease since 16:00 on August 6)	—
	Water level of Turbine Building	O.P.+ 2,650 mm (11 mm increase since 16:00 on August 6)	O.P.+ 3,269 mm (18 mm decrease since 16:00 on August 6)	O.P.+ 3,221 mm (9 mm decrease since 16:00 on August 6)	O.P.+ 3,220 mm (7 mm decrease since 16:00 on August 6)
	Water level of Reactor Building	O.P.+ 4,355 mm (15 mm increase since 16:00 on August 6)	O.P.+ 3,490 mm (20 mm decrease since 16:00 on August 6)	O.P.+ 3,359 mm (8 mm decrease since 16:00 on August 6)	O.P.+ 3,227 mm (7 mm decrease since 16:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,879 mm (Increase from initial level:6,096 mm, 4 mm increase since 16:00 on August 6) O.P.+ 3,245 mm (Increase from initial level:3,971 mm, 104 mm increase since 16:00 on August 6) O.P.+ 4,268 mm (Water level from floor:472 mm, 1 mm increase since 16:00 on August 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:13 on August 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:47 on July 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:05 on June 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:09 on July 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.