

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 8)**

Water Level of the accumulated water (at 7:00 on August 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,307 mm (41 mm increase since 16:00 on August 7)	O.P.+ 3,260 mm (12 mm increase since 16:00 on August 7)	—
	Water level of Turbine Building	O.P.+ 2,667 mm (10 mm increase since 16:00 on August 7)	O.P.+ 3,319 mm (34 mm increase since 16:00 on August 7)	O.P.+ 3,249 mm (15 mm increase since 16:00 on August 7)	O.P.+ 3,221 mm (5 mm increase since 16:00 on August 7)
	Water level of Reactor Building	O.P.+ 4,361 mm (24 mm increase since 16:00 on August 7)	O.P.+ 3,526 mm (32 mm increase since 16:00 on August 7)	O.P.+ 3,385 mm (18 mm increase since 16:00 on August 7)	O.P.+ 3,226 mm (3 mm increase since 16:00 on August 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,638 mm (Increase from initial level:5,855 mm, 175 mm decrease since 16:00 on August 7) O.P.+ 3,338 mm (Increase from initial level:4,064 mm, 39 mm increase since 16:00 on August 7) O.P.+ 4,270 mm (Water level from floor:474 mm, 1 mm increase since 16:00 on August 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:40 on August 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:00 on August 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.