

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 8)**

Water Level of the accumulated water (at 16:00 on August 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,327 mm (20 mm increase since 7:00 on August 8)	O.P.+ 3,266 mm (6 mm increase since 7:00 on August 8)	—
	Water level of Turbine Building	O.P.+ 2,674 mm (7 mm increase since 7:00 on August 8)	O.P.+ 3,339 mm (20 mm increase since 7:00 on August 8)	O.P.+ 3,256 mm (7 mm increase since 7:00 on August 8)	O.P.+ 3,226 mm (5 mm increase since 7:00 on August 8)
	Water level of Reactor Building	O.P.+ 4,339 mm (22 mm decrease since 7:00 on August 8)	O.P.+ 3,546 mm (20 mm increase since 7:00 on August 8)	O.P.+ 3,391 mm (6 mm increase since 7:00 on August 8)	O.P.+ 3,230 mm (4 mm increase since 7:00 on August 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,528 mm (Increase from initial level:5,745 mm, 110 mm decrease since 7:00 on August 8) O.P.+ 3,362 mm (Increase from initial level:4,088 mm, 24 mm increase since 7:00 on August 8) O.P.+ 4,271 mm (Water level from floor:475 mm, 1 mm increase since 7:00 on August 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:40 on August 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:00 on August 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.