

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 9)**

Water Level of the accumulated water (at 7:00 on August 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,290 mm (37 mm decrease since 16:00 on August 8)	O.P.+ 3,298 mm (32 mm increase since 16:00 on August 8)	—
	Water level of Turbine Building	O.P.+ 2,684 mm (10 mm increase since 16:00 on August 8)	O.P.+ 3,305 mm (34 mm decrease since 16:00 on August 8)	O.P.+ 3,320 mm (64 mm increase since 16:00 on August 8)	O.P.+ 3,241 mm (15 mm increase since 16:00 on August 8)
	Water level of Reactor Building	O.P.+ 4,347 mm (8 mm increase since 16:00 on August 8)	O.P.+ 3,530 mm (16 mm decrease since 16:00 on August 8)	O.P.+ 3,453 mm (62 mm increase since 16:00 on August 8)	O.P.+ 3,243 mm (13 mm increase since 16:00 on August 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,256 mm (Increase from initial level:5,473 mm, 272 mm decrease since 16:00 on August 8) O.P.+ 3,392 mm (Increase from initial level:4,118 mm, 30 mm increase since 16:00 on August 8) O.P.+ 4,272 mm (Water level from floor:476 mm, 1 mm increase since 16:00 on August 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 18:10 on August 8)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:40 on August 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:00 on August 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.