

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 10)**

Water Level of the accumulated water (at 16:00 on August 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,244 mm (17 mm increase since 7:00 on August 10)	O.P.+ 3,334 mm (2 mm decrease since 7:00 on August 10)	—
	Water level of Turbine Building	O.P.+ 2,706 mm (6 mm increase since 7:00 on August 10)	O.P.+ 3,265 mm (15 mm increase since 7:00 on August 10)	O.P.+ 3,328 mm (19 mm decrease since 7:00 on August 10)	O.P.+ 3,286 mm (10 mm increase since 7:00 on August 10)
	Water level of Reactor Building	O.P.+ 4,331 mm (9 mm decrease since 7:00 on August 10)	O.P.+ 3,475 mm (1 mm increase since 7:00 on August 10)	O.P.+ 3,475 mm (12 mm decrease since 7:00 on August 10)	O.P.+ 3,282 mm (10 mm increase since 7:00 on August 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,090 mm (Increase from initial level:5,307 mm, 23 mm increase since 7:00 on August 10) O.P.+ 3,544 mm (Increase from initial level:4,270 mm, 94 mm increase since 7:00 on August 10) O.P.+ 4,272 mm (Water level from floor:476 mm, No change since 7:00 on August 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 18:10 on August 8 to 9:23 on August 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 13:53 on August 10)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:40 on August 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:00 on August 7 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 1:35 PM on August 10, we stopped transferring the accumulated water from Unit 3 Turbine Building basement to the Central Radioactive Waste Treatment Facility (Process Main Building).				

For quick publication of the data of water level, values are provided as reference values.