

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 13)**

Water Level of the accumulated water (at 7:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,284 mm (42 mm decrease since 16:00 on August 12)	O.P.+ 3,327 mm (6 mm increase since 16:00 on August 12)	—
	Water level of Turbine Building	O.P.+ 2,748 mm (10 mm increase since 16:00 on August 12)	O.P.+ 3,300 mm (37 mm decrease since 16:00 on August 12)	O.P.+ 3,317 mm (8 mm increase since 16:00 on August 12)	O.P.+ 3,289 mm (No change since 16:00 on August 12)
	Water level of Reactor Building	O.P.+ 4,329 mm (2 mm decrease since 16:00 on August 12)	O.P.+ 3,527 mm (32 mm decrease since 16:00 on August 12)	O.P.+ 3,457 mm (10 mm increase since 16:00 on August 12)	O.P.+ 3,290 mm (No change since 16:00 on August 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,817 mm (Increase from initial level:5,034 mm, 124 mm decrease since 16:00 on August 12) O.P.+ 3,183 mm (Increase from initial level:3,909 mm, 34 mm decrease since 16:00 on August 12) O.P.+ 4,276 mm (Water level from floor:480 mm, 1 mm increase since 16:00 on August 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on August 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:40 on August 7 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 23:23 on August 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.