

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 13)**

Water Level of the accumulated water (at 16:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,261 mm (23 mm decrease since 7:00 on August 13)	O.P.+ 3,329 mm (2 mm increase since 7:00 on August 13)	—
	Water level of Turbine Building	O.P.+ 2,753 mm (5 mm increase since 7:00 on August 13)	O.P.+ 3,280 mm (20 mm decrease since 7:00 on August 13)	O.P.+ 3,319 mm (2 mm increase since 7:00 on August 13)	O.P.+ 3,293 mm (4 mm increase since 7:00 on August 13)
	Water level of Reactor Building	O.P.+ 4,330 mm (1 mm increase since 7:00 on August 13)	O.P.+ 3,506 mm (21 mm decrease since 7:00 on August 13)	O.P.+ 3,459 mm (2 mm increase since 7:00 on August 13)	O.P.+ 3,294 mm (4 mm increase since 7:00 on August 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,792 mm (Increase from initial level:5,009 mm, 25 mm decrease since 7:00 on August 13) O.P.+ 3,152 mm (Increase from initial level:3,878 mm, 31 mm decrease since 7:00 on August 13) O.P.+ 4,277 mm (Water level from floor:481 mm, 1 mm increase since 7:00 on August 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:00 on August 12)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 23:23 on August 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.