

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 15)**

Water Level of the accumulated water (at 7:00 on August 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,262 mm (43 mm increase since 16:00 on August 14)	O.P.+ 3,326 mm (10 mm decrease since 16:00 on August 14)	—
	Water level of Turbine Building	O.P.+ 2,776 mm (7 mm increase since 16:00 on August 14)	O.P.+ 3,281 mm (38 mm increase since 16:00 on August 14)	O.P.+ 3,303 mm (17 mm decrease since 16:00 on August 14)	O.P.+ 3,295 mm (7 mm decrease since 16:00 on August 14)
	Water level of Reactor Building	O.P.+ 4,320 mm (20 mm decrease since 16:00 on August 14)	O.P.+ 3,488 mm (33 mm increase since 16:00 on August 14)	O.P.+ 3,445 mm (18 mm decrease since 16:00 on August 14)	O.P.+ 3,297 mm (4 mm decrease since 16:00 on August 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,807 mm (Increase from initial level:5,024 mm, 4 mm increase since 16:00 on August 14) O.P.+ 2,747 mm (Increase from initial level:3,473 mm, 251 mm decrease since 16:00 on August 14) O.P.+ 4,281 mm (Water level from floor:485 mm, 3 mm increase since 16:00 on August 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 23:23 on August 11   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.