

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 16)**

Water Level of the accumulated water (at 7:00 on August 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,265 mm (16 mm decrease since 16:00 on August 15)	O.P.+ 3,313 mm (10 mm decrease since 16:00 on August 15)	—
	Water level of Turbine Building	O.P.+ 2,790 mm (8 mm increase since 16:00 on August 15)	O.P.+ 3,281 mm (20 mm decrease since 16:00 on August 15)	O.P.+ 3,285 mm (10 mm decrease since 16:00 on August 15)	O.P.+ 3,281 mm (11 mm decrease since 16:00 on August 15)
	Water level of Reactor Building	O.P.+ 4,309 mm (5 mm increase since 16:00 on August 15)	O.P.+ 3,497 mm (9 mm decrease since 16:00 on August 15)	O.P.+ 3,425 mm (12 mm decrease since 16:00 on August 15)	O.P.+ 3,285 mm (6 mm decrease since 16:00 on August 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,815 mm (Increase from initial level:5,032 mm, 5 mm increase since 16:00 on August 15) O.P.+ 2,667 mm (Increase from initial level:3,393 mm, 41 mm increase since 16:00 on August 15) O.P.+ 4,285 mm (Water level from floor:489 mm, 3 mm increase since 16:00 on August 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 23:23 on August 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.