

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 16)**

Water Level of the accumulated water (at 16:00 on August 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,254 mm (11 mm decrease since 7:00 on August 16)	O.P.+ 3,309 mm (4 mm decrease since 7:00 on August 16)	—
	Water level of Turbine Building	O.P.+ 2,795 mm (5 mm increase since 7:00 on August 16)	O.P.+ 3,271 mm (10 mm decrease since 7:00 on August 16)	O.P.+ 3,277 mm (8 mm decrease since 7:00 on August 16)	O.P.+ 3,276 mm (5 mm decrease since 7:00 on August 16)
	Water level of Reactor Building	O.P.+ 4,305 mm (4 mm decrease since 7:00 on August 16)	O.P.+ 3,490 mm (7 mm decrease since 7:00 on August 16)	O.P.+ 3,420 mm (5 mm decrease since 7:00 on August 16)	O.P.+ 3,280 mm (5 mm decrease since 7:00 on August 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,817 mm (Increase from initial level:5,034 mm, 2 mm increase since 7:00 on August 16) O.P.+ 2,700 mm (Increase from initial level:3,426 mm, 33 mm increase since 7:00 on August 16) O.P.+ 4,286 mm (Water level from floor:490 mm, 1 mm increase since 7:00 on August 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 23:23 on August 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.