

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 17)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on August 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,225 mm (10 mm decrease since 7:00 on August 17)	O.P.+ 3,293 mm (7 mm decrease since 7:00 on August 17)	—
	Water level of Turbine Building	O.P.+ 2,807 mm (4 mm increase since 7:00 on August 17)	O.P.+ 3,245 mm (10 mm decrease since 7:00 on August 17)	O.P.+ 3,262 mm (3 mm decrease since 7:00 on August 17)	O.P.+ 3,261 mm (5 mm decrease since 7:00 on August 17)
	Water level of Reactor Building	O.P.+ 4,309 mm (18 mm decrease since 7:00 on August 17)	O.P.+ 3,464 mm (8 mm decrease since 7:00 on August 17)	O.P.+ 3,403 mm (5 mm decrease since 7:00 on August 17)	O.P.+ 3,264 mm (6 mm decrease since 7:00 on August 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,842 mm (Increase from initial level:5,059 mm, 21 mm increase since 7:00 on August 17) O.P.+ 3,007 mm (Increase from initial level:3,733 mm, 257 mm increase since 7:00 on August 17) O.P.+ 4,291 mm (Water level from floor:495 mm, 2 mm increase since 7:00 on August 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:42 on August 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes	- At 7:30 AM on August 17, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. After the filter cleaning, the apparatus was restarted at 11:42 AM on the same day, and the steady flow rate was achieved.				

For quick publication of the data of water level, values are provided as reference values.