

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 20)**

Water Level of the accumulated water (at 7:00 on August 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,152 mm (18 mm decrease since 16:00 on August 19)	O.P.+ 3,259 mm (8 mm decrease since 16:00 on August 19)	—
	Water level of Turbine Building	O.P.+ 2,840 mm (7 mm increase since 16:00 on August 19)	O.P.+ 3,180 mm (15 mm decrease since 16:00 on August 19)	O.P.+ 3,223 mm (9 mm decrease since 16:00 on August 19)	O.P.+ 3,223 mm (8 mm decrease since 16:00 on August 19)
	Water level of Reactor Building	O.P.+ 4,288 mm (9 mm increase since 16:00 on August 19)	O.P.+ 3,400 mm (16 mm decrease since 16:00 on August 19)	O.P.+ 3,366 mm (8 mm decrease since 16:00 on August 19)	O.P.+ 3,229 mm (10 mm decrease since 16:00 on August 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,839 mm (Increase from initial level:5,056 mm, 3 mm increase since 16:00 on August 19) O.P.+ 3,237 mm (Increase from initial level:3,963 mm, 53 mm increase since 16:00 on August 19) O.P.+ 4,301 mm (Water level from floor:505 mm, 2 mm increase since 16:00 on August 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:08 on August 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:42 on August 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.