

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 21)**

Water Level of the accumulated water (at 16:00 on August 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,140 mm (16 mm increase since 7:00 on August 21)	O.P.+ 3,240 mm (4 mm decrease since 7:00 on August 21)	—
	Water level of Turbine Building	O.P.+ 2,856 mm (4 mm increase since 7:00 on August 21)	O.P.+ 3,169 mm (14 mm increase since 7:00 on August 21)	O.P.+ 3,205 mm (4 mm decrease since 7:00 on August 21)	O.P.+ 3,204 mm (5 mm decrease since 7:00 on August 21)
	Water level of Reactor Building	O.P.+ 4,261 mm (27 mm decrease since 7:00 on August 21)	O.P.+ 3,379 mm (4 mm increase since 7:00 on August 21)	O.P.+ 3,346 mm (5 mm decrease since 7:00 on August 21)	O.P.+ 3,211 mm (6 mm decrease since 7:00 on August 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,847 mm (Increase from initial level:5,064 mm, 2 mm increase since 7:00 on August 21) O.P.+ 3,213 mm (Increase from initial level:3,939 mm, 112 mm decrease since 7:00 on August 21) O.P.+ 4,305 mm (Water level from floor:509 mm, 2 mm increase since 7:00 on August 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 17:08 on August 15 to 9:57 on August 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:42 on August 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.