

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 22)**

Water Level of the accumulated water (at 16:00 on August 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,177 mm (1 mm increase since 7:00 on August 22)	O.P.+ 3,228 mm (3 mm decrease since 7:00 on August 22)	—
	Water level of Turbine Building	O.P.+ 2,867 mm (4 mm increase since 7:00 on August 22)	O.P.+ 3,203 mm (1 mm increase since 7:00 on August 22)	O.P.+ 3,190 mm (4 mm decrease since 7:00 on August 22)	O.P.+ 3,190 mm (5 mm decrease since 7:00 on August 22)
	Water level of Reactor Building	O.P.+ 4,256 mm (12 mm decrease since 7:00 on August 22)	O.P.+ 3,421 mm (9 mm increase since 7:00 on August 22)	O.P.+ 3,331 mm (5 mm decrease since 7:00 on August 22)	O.P.+ 3,199 mm (5 mm decrease since 7:00 on August 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,903 mm (Increase from initial level:5,120 mm, 52 mm increase since 7:00 on August 22) O.P.+ 2,773 mm (Increase from initial level:3,499 mm, 146 mm decrease since 7:00 on August 22) O.P.+ 4,308 mm (Water level from floor:512 mm, 1 mm increase since 7:00 on August 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:22 on August 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:42 on August 17   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.