

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 23)**

Water Level of the accumulated water (at 16:00 on August 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,139 mm (14 mm decrease since 7:00 on August 23)	O.P.+ 3,215 mm (4 mm decrease since 7:00 on August 23)	—
	Water level of Turbine Building	O.P.+ 2,879 mm (4 mm increase since 7:00 on August 23)	O.P.+ 3,170 mm (11 mm decrease since 7:00 on August 23)	O.P.+ 3,175 mm (6 mm decrease since 7:00 on August 23)	O.P.+ 3,177 mm (4 mm decrease since 7:00 on August 23)
	Water level of Reactor Building	O.P.+ 4,266 mm (16 mm decrease since 7:00 on August 23)	O.P.+ 3,390 mm (10 mm decrease since 7:00 on August 23)	O.P.+ 3,317 mm (6 mm decrease since 7:00 on August 23)	O.P.+ 3,186 mm (5 mm decrease since 7:00 on August 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,169 mm (Increase from initial level:5,386 mm, 98 mm increase since 7:00 on August 23) O.P.+ 2,435 mm (Increase from initial level:3,161 mm, 121 mm decrease since 7:00 on August 23) O.P.+ 4,310 mm (Water level from floor:514 mm, No change since 7:00 on August 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:22 on August 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:42 on August 17 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.