

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 24)**

Water Level of the accumulated water (at 7:00 on August 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,118 mm (21 mm decrease since 16:00 on August 23)	O.P.+ 3,207 mm (8 mm decrease since 16:00 on August 23)	—
	Water level of Turbine Building	O.P.+ 2,887 mm (8 mm increase since 16:00 on August 23)	O.P.+ 3,151 mm (19 mm decrease since 16:00 on August 23)	O.P.+ 3,167 mm (8 mm decrease since 16:00 on August 23)	O.P.+ 3,168 mm (9 mm decrease since 16:00 on August 23)
	Water level of Reactor Building	O.P.+ 4,280 mm (14 mm increase since 16:00 on August 23)	O.P.+ 3,372 mm (18 mm decrease since 16:00 on August 23)	O.P.+ 3,310 mm (7 mm decrease since 16:00 on August 23)	O.P.+ 3,177 mm (9 mm decrease since 16:00 on August 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,345 mm (Increase from initial level:5,562 mm, 176 mm increase since 16:00 on August 23) O.P.+ 2,229 mm (Increase from initial level:2,955 mm, 206 mm decrease since 16:00 on August 23) O.P.+ 4,312 mm (Water level from floor:516 mm, 2 mm increase since 16:00 on August 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:22 on August 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on August 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:45 on August 24 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:45 AM on August 24, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.