

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 27)**

Water Level of the accumulated water (at 7:00 on August 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,155 mm (35 mm increase since 16:00 on August 26)	O.P.+ 3,165 mm (9 mm decrease since 16:00 on August 26)	—
	Water level of Turbine Building	O.P.+ 2,540 mm (8 mm increase since 16:00 on August 26)	O.P.+ 3,184 mm (31 mm increase since 16:00 on August 26)	O.P.+ 3,124 mm (11 mm decrease since 16:00 on August 26)	O.P.+ 3,126 mm (9 mm decrease since 16:00 on August 26)
	Water level of Reactor Building	O.P.+ 4,283 mm (32 mm increase since 16:00 on August 26)	O.P.+ 3,394 mm (31 mm increase since 16:00 on August 26)	O.P.+ 3,257 mm (11 mm decrease since 16:00 on August 26)	O.P.+ 3,137 mm (10 mm decrease since 16:00 on August 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,339 mm (Increase from initial level:5,556 mm, 149 mm decrease since 16:00 on August 26) O.P.+ 2,439 mm (Increase from initial level:3,165 mm, 31 mm increase since 16:00 on August 26) O.P.+ 4,323 mm (Water level from floor:527 mm, 3 mm increase since 16:00 on August 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:09 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.