

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 27)**

Water Level of the accumulated water (at 16:00 on August 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,175 mm (20 mm increase since 7:00 on August 27)	O.P.+ 3,160 mm (5 mm decrease since 7:00 on August 27)	—
	Water level of Turbine Building	O.P.+ 2,544 mm (4 mm increase since 7:00 on August 27)	O.P.+ 3,201 mm (17 mm increase since 7:00 on August 27)	O.P.+ 3,119 mm (5 mm decrease since 7:00 on August 27)	O.P.+ 3,120 mm (6 mm decrease since 7:00 on August 27)
	Water level of Reactor Building	O.P.+ 4,271 mm (12 mm decrease since 7:00 on August 27)	O.P.+ 3,411 mm (17 mm increase since 7:00 on August 27)	O.P.+ 3,252 mm (5 mm decrease since 7:00 on August 27)	O.P.+ 3,131 mm (6 mm decrease since 7:00 on August 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,252 mm (Increase from initial level:5,469 mm, 87 mm decrease since 7:00 on August 27) O.P.+ 2,463 mm (Increase from initial level:3,189 mm, 24 mm increase since 7:00 on August 27) O.P.+ 4,324 mm (Water level from floor:528 mm, 1 mm increase since 7:00 on August 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:09 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.