

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 28)**

Water Level of the accumulated water (at 7:00 on August 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,207 mm (32 mm increase since 16:00 on August 27)	O.P.+ 3,149 mm (11 mm decrease since 16:00 on August 27)	—
	Water level of Turbine Building	O.P.+ 2,550 mm (6 mm increase since 16:00 on August 27)	O.P.+ 3,229 mm (28 mm increase since 16:00 on August 27)	O.P.+ 3,108 mm (11 mm decrease since 16:00 on August 27)	O.P.+ 3,109 mm (11 mm decrease since 16:00 on August 27)
	Water level of Reactor Building	O.P.+ 4,309 mm (38 mm increase since 16:00 on August 27)	O.P.+ 3,440 mm (29 mm increase since 16:00 on August 27)	O.P.+ 3,242 mm (10 mm decrease since 16:00 on August 27)	O.P.+ 3,121 mm (10 mm decrease since 16:00 on August 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,110 mm (Increase from initial level:5,327 mm, 142 mm decrease since 16:00 on August 27) O.P.+ 2,494 mm (Increase from initial level:3,220 mm, 31 mm increase since 16:00 on August 27) O.P.+ 4,326 mm (Water level from floor:530 mm, 2 mm increase since 16:00 on August 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:09 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.