

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 28)**

Water Level of the accumulated water (at 16:00 on August 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,202 mm (5 mm decrease since 7:00 on August 28)	O.P.+ 3,144 mm (5 mm decrease since 7:00 on August 28)	—
	Water level of Turbine Building	O.P.+ 2,553 mm (3 mm increase since 7:00 on August 28)	O.P.+ 3,225 mm (4 mm decrease since 7:00 on August 28)	O.P.+ 3,103 mm (5 mm decrease since 7:00 on August 28)	O.P.+ 3,103 mm (6 mm decrease since 7:00 on August 28)
	Water level of Reactor Building	O.P.+ 4,295 mm (14 mm decrease since 7:00 on August 28)	O.P.+ 3,445 mm (5 mm increase since 7:00 on August 28)	O.P.+ 3,238 mm (4 mm decrease since 7:00 on August 28)	O.P.+ 3,115 mm (6 mm decrease since 7:00 on August 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,088 mm (Increase from initial level:5,305 mm, 22 mm decrease since 7:00 on August 28) O.P.+ 2,515 mm (Increase from initial level:3,241 mm, 21 mm increase since 7:00 on August 28) O.P.+ 4,329 mm (Water level from floor:533 mm, 3 mm increase since 7:00 on August 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:26 on August 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:09 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.