

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 29)**

Water Level of the accumulated water (at 7:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,178 mm (24 mm decrease since 16:00 on August 28)	O.P.+ 3,134 mm (10 mm decrease since 16:00 on August 28)	—
	Water level of Turbine Building	O.P.+ 2,560 mm (7 mm increase since 16:00 on August 28)	O.P.+ 3,203 mm (22 mm decrease since 16:00 on August 28)	O.P.+ 3,093 mm (10 mm decrease since 16:00 on August 28)	O.P.+ 3,093 mm (10 mm decrease since 16:00 on August 28)
	Water level of Reactor Building	O.P.+ 4,315 mm (20 mm increase since 16:00 on August 28)	O.P.+ 3,427 mm (18 mm decrease since 16:00 on August 28)	O.P.+ 3,227 mm (11 mm decrease since 16:00 on August 28)	O.P.+ 3,107 mm (8 mm decrease since 16:00 on August 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,112 mm (Increase from initial level:5,329 mm, 24 mm increase since 16:00 on August 28) O.P.+ 2,547 mm (Increase from initial level:3,273 mm, 32 mm increase since 16:00 on August 28) O.P.+ 4,331 mm (Water level from floor:535 mm, 2 mm increase since 16:00 on August 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:26 on August 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 13:09 on August 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.