

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 29)**

Water Level of the accumulated water (at 16:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,165 mm (13 mm decrease since 7:00 on August 29)	O.P.+ 3,130 mm (4 mm decrease since 7:00 on August 29)	—
	Water level of Turbine Building	O.P.+ 2,565 mm (5 mm increase since 7:00 on August 29)	O.P.+ 3,192 mm (11 mm decrease since 7:00 on August 29)	O.P.+ 3,091 mm (2 mm decrease since 7:00 on August 29)	O.P.+ 3,088 mm (5 mm decrease since 7:00 on August 29)
	Water level of Reactor Building	O.P.+ 4,314 mm (1 mm decrease since 7:00 on August 29)	O.P.+ 3,415 mm (12 mm decrease since 7:00 on August 29)	O.P.+ 3,226 mm (1 mm decrease since 7:00 on August 29)	O.P.+ 3,101 mm (6 mm decrease since 7:00 on August 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,112 mm (Increase from initial level:5,329 mm, No change since 7:00 on August 29) O.P.+ 2,567 mm (Increase from initial level:3,293 mm, 20 mm increase since 7:00 on August 29) O.P.+ 4,333 mm (Water level from floor:537 mm, 2 mm increase since 7:00 on August 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:26 on August 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) #N/A (Since 12:52 on August 29)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 11:06 AM on August 29, transfer of the accumulated water from Unit 3 Turbine Building basement to Central Radioactive Waste Treatment Facility (Process Main Building) was temporarily suspended due to the replacement work of the accumulated water transferring pipes to polyethylene pipes.				

For quick publication of the data of water level, values are provided as reference values.