

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 30)**

Water Level of the accumulated water (at 7:00 on August 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,146 mm (19 mm decrease since 16:00 on August 29)	O.P.+ 3,119 mm (11 mm decrease since 16:00 on August 29)	—
	Water level of Turbine Building	O.P.+ 2,570 mm (5 mm increase since 16:00 on August 29)	O.P.+ 3,174 mm (18 mm decrease since 16:00 on August 29)	O.P.+ 3,076 mm (15 mm decrease since 16:00 on August 29)	O.P.+ 3,079 mm (9 mm decrease since 16:00 on August 29)
	Water level of Reactor Building	O.P.+ 4,329 mm (15 mm increase since 16:00 on August 29)	O.P.+ 3,397 mm (18 mm decrease since 16:00 on August 29)	O.P.+ 3,211 mm (15 mm decrease since 16:00 on August 29)	O.P.+ 3,092 mm (9 mm decrease since 16:00 on August 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,149 mm (Increase from initial level:5,366 mm, 37 mm increase since 16:00 on August 29) O.P.+ 2,601 mm (Increase from initial level:3,327 mm, 34 mm increase since 16:00 on August 29) O.P.+ 4,336 mm (Water level from floor:540 mm, 3 mm increase since 16:00 on August 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 10:26 on August 28 to 8:47 on August 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 12:52 on August 29 to 8:52 on August 30)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:32 on August 24   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.