

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 31)**

Water Level of the accumulated water (at 7:00 on August 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,203 mm (37 mm increase since 16:00 on August 30)	O.P.+ 3,102 mm (13 mm decrease since 16:00 on August 30)	—
	Water level of Turbine Building	O.P.+ 2,581 mm (7 mm increase since 16:00 on August 30)	O.P.+ 3,225 mm (32 mm increase since 16:00 on August 30)	O.P.+ 3,091 mm (1 mm increase since 16:00 on August 30)	O.P.+ 3,035 mm (34 mm decrease since 16:00 on August 30)
	Water level of Reactor Building	O.P.+ 4,338 mm (17 mm increase since 16:00 on August 30)	O.P.+ 3,438 mm (34 mm increase since 16:00 on August 30)	O.P.+ 3,227 mm (5 mm increase since 16:00 on August 30)	O.P.+ 3,052 mm (33 mm decrease since 16:00 on August 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,754 mm (Increase from initial level:4,971 mm, 270 mm decrease since 16:00 on August 30) O.P.+ 3,105 mm (Increase from initial level:3,831 mm, 433 mm increase since 16:00 on August 30) O.P.+ 4,339 mm (Water level from floor:543 mm, 1 mm increase since 16:00 on August 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Turbine Building Basement the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:15 on August 30)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:34 on August 31 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:34 AM on August 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

For quick publication of the data of water level, values are provided as reference values.