

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on August 31)**

Water Level of the accumulated water (at 16:00 on August 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,225 mm (22 mm increase since 7:00 on August 31)	O.P.+ 3,095 mm (7 mm decrease since 7:00 on August 31)	—
	Water level of Turbine Building	O.P.+ 2,584 mm (3 mm increase since 7:00 on August 31)	O.P.+ 3,244 mm (19 mm increase since 7:00 on August 31)	O.P.+ 3,088 mm (3 mm decrease since 7:00 on August 31)	O.P.+ 3,019 mm (16 mm decrease since 7:00 on August 31)
	Water level of Reactor Building	O.P.+ 4,344 mm (6 mm increase since 7:00 on August 31)	O.P.+ 3,457 mm (19 mm increase since 7:00 on August 31)	O.P.+ 3,223 mm (4 mm decrease since 7:00 on August 31)	O.P.+ 3,036 mm (16 mm decrease since 7:00 on August 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,755 mm (Increase from initial level:4,972 mm, 1 mm increase since 7:00 on August 31) O.P.+ 3,337 mm (Increase from initial level:4,063 mm, 232 mm increase since 7:00 on August 31) O.P.+ 4,341 mm (Water level from floor:545 mm, 2 mm increase since 7:00 on August 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Turbine Building Basement the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:15 on August 30)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:52 on August 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 7:34 AM on August 31, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning. After the filter cleaning, the apparatus was restarted at 4:00 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.