

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 3)**

Water Level of the accumulated water (at 16:00 on September 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (24 mm increase since 7:00 on September 3)	O.P.+ 3,137 mm (No change since 7:00 on September 3)	—
	Water level of Turbine Building	O.P.+ 2,612 mm (3 mm increase since 7:00 on September 3)	O.P.+ 3,186 mm (20 mm increase since 7:00 on September 3)	O.P.+ 3,182 mm (18 mm decrease since 7:00 on September 3)	O.P.+ 2,869 mm (13 mm decrease since 7:00 on September 3)
	Water level of Reactor Building	O.P.+ 4,354 mm (19 mm decrease since 7:00 on September 3)	O.P.+ 3,404 mm (4 mm increase since 7:00 on September 3)	O.P.+ 3,329 mm (9 mm decrease since 7:00 on September 3)	O.P.+ 2,893 mm (14 mm decrease since 7:00 on September 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,777 mm (Increase from initial level:4,994 mm, 3 mm increase since 7:00 on September 3) O.P.+ 3,515 mm (Increase from initial level:4,241 mm, 18 mm increase since 7:00 on September 3) O.P.+ 4,353 mm (Water level from floor:557 mm, 2 mm increase since 7:00 on September 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:15 on August 30)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:52 on August 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.