

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 4)**

|  |  |  |   |   |   |
|--|--|--|---|---|---|
| Water Level of the accumulated water<br>(at 7:00 on September 4) |  | Unit 1   | Unit 2  | Unit 3  | Unit 4  |
|  | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,199 mm<br>(40 mm increase since 16:00 on September 3)   | O.P.+ 3,117 mm<br>(20 mm decrease since 16:00 on September 3) | —   |
|  | Water level of Turbine Building  | O.P.+ 2,618 mm<br>(6 mm increase since 16:00 on September 3)   | O.P.+ 3,222 mm<br>(36 mm increase since 16:00 on September 3)   | O.P.+ 3,150 mm<br>(32 mm decrease since 16:00 on September 3) | O.P.+ 2,850 mm<br>(19 mm decrease since 16:00 on September 3)   |
|  | Water level of Reactor Building  | O.P.+ 4,382 mm<br>(28 mm increase since 16:00 on September 3)  | O.P.+ 3,440 mm<br>(36 mm increase since 16:00 on September 3)   | O.P.+ 3,295 mm<br>(34 mm decrease since 16:00 on September 3) | O.P.+ 2,873 mm<br>(20 mm decrease since 16:00 on September 3)   |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building  | O.P.+ 3,780 mm (Increase from initial level:4,997 mm, 3 mm increase since 16:00 on September 3)<br>O.P.+ 3,528 mm (Increase from initial level:4,254 mm, 13 mm increase since 16:00 on September 3)<br>O.P.+ 4,355 mm (Water level from floor:559 mm, 2 mm increase since 16:00 on September 3) |   |   |
| Situation of transfer of the accumulated water                   |  | Unit 1   | Unit 2  | Unit 3  | Unit 4  |
|  |  | —  | —   | —   | Basement of Unit 4 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 16:15 on August 30) |
|  |  | Unit 5 and 6   |   |   |   |
|  |  | —  |   |   |   |
| Operation condition of water treatment facility                  |  | Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 15:52 on August 31   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |   |   |
| Notes  |  |  |   |   |   |

※ For quick publication of the data of water level, values are provided as reference values.