

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 5)**

Water Level of the accumulated water (at 7:00 on September 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,266 mm (44 mm increase since 16:00 on September 4)	O.P.+ 3,099 mm (4 mm decrease since 16:00 on September 4)	—
	Water level of Turbine Building	O.P.+ 2,628 mm (7 mm increase since 16:00 on September 4)	O.P.+ 3,281 mm (40 mm increase since 16:00 on September 4)	O.P.+ 3,121 mm (14 mm decrease since 16:00 on September 4)	O.P.+ 2,863 mm (25 mm increase since 16:00 on September 4)
	Water level of Reactor Building	O.P.+ 4,482 mm (104 mm increase since 16:00 on September 4)	O.P.+ 3,497 mm (36 mm increase since 16:00 on September 4)	O.P.+ 3,264 mm (12 mm decrease since 16:00 on September 4)	O.P.+ 2,882 mm (18 mm increase since 16:00 on September 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,785 mm (Increase from initial level:5,002 mm, 3 mm increase since 16:00 on September 4) O.P.+ 3,199 mm (Increase from initial level:3,925 mm, 334 mm decrease since 16:00 on September 4) O.P.+ 4,359 mm (Water level from floor:563 mm, 3 mm increase since 16:00 on September 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:31 on September 4)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:52 on August 31 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.