

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on September 5)**

Water Level of the accumulated water (at 16:00 on September 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,290 mm (24 mm increase since 7:00 on September 5)	O.P.+ 3,093 mm (6 mm decrease since 7:00 on September 5)	—
	Water level of Turbine Building	O.P.+ 2,632 mm (4 mm increase since 7:00 on September 5)	O.P.+ 3,302 mm (21 mm increase since 7:00 on September 5)	O.P.+ 3,109 mm (12 mm decrease since 7:00 on September 5)	O.P.+ 2,871 mm (8 mm increase since 7:00 on September 5)
	Water level of Reactor Building	O.P.+ 4,504 mm (22 mm increase since 7:00 on September 5)	O.P.+ 3,518 mm (21 mm increase since 7:00 on September 5)	O.P.+ 3,250 mm (14 mm decrease since 7:00 on September 5)	O.P.+ 2,892 mm (10 mm increase since 7:00 on September 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,787 mm (Increase from initial level:5,004 mm, 2 mm increase since 7:00 on September 5) O.P.+ 3,025 mm (Increase from initial level:3,751 mm, 174 mm decrease since 7:00 on September 5) O.P.+ 4,361 mm (Water level from floor:565 mm, 2 mm increase since 7:00 on September 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 17:10 on September 5)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:31 on September 4)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:52 on August 31   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.