

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 6)**

Water Level of the accumulated water (at 7:00 on September 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,251 mm (39 mm decrease since 16:00 on September 5)	O.P.+ 3,112 mm (19 mm increase since 16:00 on September 5)	—
	Water level of Turbine Building	O.P.+ 2,640 mm (8 mm increase since 16:00 on September 5)	O.P.+ 3,269 mm (33 mm decrease since 16:00 on September 5)	O.P.+ 3,155 mm (46 mm increase since 16:00 on September 5)	O.P.+ 2,880 mm (9 mm increase since 16:00 on September 5)
	Water level of Reactor Building	O.P.+ 4,548 mm (44 mm increase since 16:00 on September 5)	O.P.+ 3,501 mm (17 mm decrease since 16:00 on September 5)	O.P.+ 3,290 mm (40 mm increase since 16:00 on September 5)	O.P.+ 2,900 mm (8 mm increase since 16:00 on September 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,791 mm (Increase from initial level:5,008 mm, 4 mm increase since 16:00 on September 5) O.P.+ 2,785 mm (Increase from initial level:3,511 mm, 240 mm decrease since 16:00 on September 5) O.P.+ 4,364 mm (Water level from floor:568 mm, 3 mm increase since 16:00 on September 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 17:10 on September 5)	—	Basement of Unit 4 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:31 on September 4)
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:57 on August 13 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:36 on September 6 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	– At 7:36 AM on September 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.